

# Consultee Comment for planning application 6/2020/3258/FULL

<b>Application Number</b>	6/2020/3258/FULL
<b>Location</b>	Woodside House Bridge Road Welwyn Garden City AL8 6UJ
<b>Proposal</b>	Construction of timber boarded bin store
<b>Case Officer</b>	Mrs Sarah Madyausiku
<b>Organisation</b>	WHBC - Client Services
<b>Name</b>	Lorraine Davis
<b>Address</b>	Client Services The Campus Welwyn Garden City AL8 6AE
<b>Type of Comment</b>	ConditionalResponse
<b>Type</b>	
<b>Comments</b>	11/01/2021 - Lorraine Davis The style/design and location of the new bin store looks good. My question would be how did you conclude the number of receptacles you will need for the whole site. Is this based on what is currently being used? If so what exactly are the bins i.e. How many 1100l containers, how many Mini Recycling Centres or Blue lidded recycling bins have been accounted for versus the accommodation schedule of the site. Also has any provision been made for food waste (our newest service). For shared facilities we have been allowing one 240l food waste bin per 10 dwellings. Perhaps if you can confirm the accomm schedule i.e. how many 1 bed, 2 bed properties etc and the bins you have designed into this application so we can be sure there is sufficient capacity. Thanks Lorraine
<b>Received Date</b>	11/01/2021 12:04:16
<b>Attachments</b>	