

From: [Matt Leighton](#) on behalf of [Town Planning LNE](#)
To: [Planning](#)
Subject: Ref 6/2021/0671/MAJ - residential development, South Side, Former Shredded Wheat Factory, Broadwater Road, Welwyn Garden City
Date: 23 March 2021 11:08:40
Attachments: [image001.png](#)
[Standard InformationUser.docx](#)

**** WARNING: This email originated outside the WHBC Network. Please be extra vigilant when opening attachments or clicking links ****

Network Rail Consultation Response

FAO:	Ms Clare Howe
Date:	23 March 2021
Application reference:	6/2021/0671/MAJ
Proposal:	Erection of 317 dwellings and outline planning for up to 404 dwellings
Location:	South Side, Former Shredded Wheat Factory, Broadwater Road, Welwyn Garden City, AL7 1RR

Thank you for giving us the opportunity to comment on the proposal.

You will be aware of our previous responses to the pre-application consultations issues in respect of the site.

We have previously indicated our concern that the existing S106 funding for footbridge improvements is insufficient to provide full Equality Act accessibility to the bridge itself. Although the main structure has now been refurbished utilising some of the funding provided in the S106 Agreement we note the funding of a lift and improved staircase is not addressed in the planning statement but merely says that it is planned - but we would question how the improvements to mobility impaired pedestrians is going to be addressed given the remaining funding in the existing S106 pot is considered insufficient to deliver the suggested improvements.

Below are some further requirements which must be met:

Works in Proximity to the Operational Railway Environment

Development Construction Phase and Asset Protection

Due to the proximity of the proposed development to the operational railway boundary, it will be imperative that the developer liaise with our Asset Protection Team (contact details below) prior to any work taking place on site to ensure that the development can be undertaken safely and without impact to operational railway safety. Details to be discussed and agreed will include construction methodology, earthworks and excavations, use of crane, plant and machinery, drainage and boundary treatments. It may be necessary for the developer to enter into a Basic Asset Protection Agreement (BAPA) with Network Rail to ensure the safety of the operational railway during these works.

Condition

Development shall not commence until a construction methodology has been submitted to and approved in writing by the Local Authority. The construction methodology shall demonstrate consultation with the Asset Protection Project Manager at Network Rail. The development shall thereafter be carried out in accordance with the approved construction methodology unless otherwise agreed in writing by the Local Planning Authority.

Contact details for Asset Protection are supplied below and **we would draw the developers' attention to the attached guidance on Network Rail requirements.**

Reason for above conditions:

The safety, operational needs and integrity of the railway.

Informatives:

Please see attached standard railway requirements to be included as informatives.

Conclusion

Thank you again for the opportunity to comment on the proposed scheme. We trust that the above will be given due consideration in determining the application and if you have any enquiries in relation to the above, please contact us at townplanninglne@networkrail.co.uk.

Useful Network Rail contacts:

Asset Protection Eastern

For enquiries, advice and agreements relating to construction methodology, works in proximity to the railway boundary, drainage works, or schemes in proximity to railway tunnels (including tunnel shafts) please email assetprotectioneastern@networkrail.co.uk.

Land Information

For enquiries relating to land ownership enquiries, please email landinformation@networkrail.co.uk.

Property Services

For enquiries relating to agreements to use, purchase or rent Network Rail land, please email propertyservicesneem@networkrail.co.uk.

Kind regards



Matt Leighton
Town Planning Technician
Diversity and Inclusion Champion
Network Rail Property - Eastern Region
George Stephenson House, Toft Green, York, YO1 6JT

The content of this email (and any attachment) is confidential. It may also be legally privileged or otherwise protected from disclosure.
This email should not be used by anyone who is not an original intended recipient, nor may it be copied or disclosed to anyone who is not an original intended recipient.

If you have received this email by mistake please notify us by emailing the sender, and then delete the email and any copies from your system.

Liability cannot be accepted for statements made which are clearly the sender's own and not made on behalf of Network Rail.
Network Rail Infrastructure Limited registered in England and Wales No. 2904587, registered office Network Rail, 2nd Floor, One Eversholt Street, London, NW1 2DN
