

CAMPUS WEST, WELWYN GARDEN CITY

PLANT NOISE ASSESSMENT - SEPTEMBER 2021 UPDATE

On behalf of:  
Press & Starkey

**CAMPUS WEST, WELWYN GARDEN CITY**  
**PLANT NOISE ASSESSMENT - SEPTEMBER 2021 UPDATE**

Report prepared by:  
Hepworth Acoustics Ltd  
1<sup>st</sup> Floor, Aztec Centre  
Aztec West  
Almondsbury  
Bristol BS32 4TD

On behalf of:  
Press & Starkey

Report prepared by:  
Samuel Oates BSc MSc MIOA - Consultant

Report checked by:  
Graham Bowland BSc MIOA - Technical Director

## **CONTENTS**

1.0	INTRODUCTION	1
2.0	BRITISH STANDARD 4142:2014+A1:2019	3
3.0	AMBIENT NOISE SURVEY	5
4.0	ASSESSMENT OF PLANT NOISE	6
5.0	SUMMARY & CONCLUSION	9
FIGURE 1: AERIAL VIEW & NOISE SURVEY LOCATION		10
FIGURE 2: PROPOSED PLANT EQUIPMENT LAYOUT		11
FIGURE 3: ILLUSTRATIVE RECOMMENDATIONS		12
APPENDIX I: NOISE UNITS & INDICES		13
APPENDIX II: NOISE SURVEY RESULTS		15

## 1.0 INTRODUCTION

- 1.1 Hepworth Acoustics Ltd was commissioned by Press & Starkey to carry out a noise impact assessment in connection with a planning application for proposed new externally mounted plant at the Campus West in Welwyn Garden City.
- 1.2 The original version of this report (ref: 'P21-118-R02v1') dated March 2021, provided an assessment of the potential noise impact from the proposed plant upon the nearest dwellings and provided recommendations for noise mitigation measures. This report update has been prepared to take into account the changes to the proposals since our original report was issued and lower plant noise design targets provided by the Environmental Health Officer (EHO).
- 1.3 The findings of the original report indicated that there was the potential for the operation of the proposed Air Source Heat Pumps (ASHPs) during the night-time (i.e. 23:00-07:00) to result a significant adverse noise impact at the nearest residential properties. We understand that the noise mitigation measures that would be needed in order for the ASHP to operate during night-time hours would be prohibitively costly. Based on these initial findings, the proposals have been refined, reduced from two ASHPs to one, the location of the ASHP has been moved further from the nearest dwellings on Scholars Mews, and the ASHP will be programmed so that it will not operate during night-time hours.
- 1.4 Therefore, on the basis that the ASHP will not operate during night-time hours, we have carried out additional background noise surveys in order to assess the potential noise impact from daytime and evening operations of the proposed ASHP.
- 1.5 The location of the Campus West is shown in Figure 1 within the context of the surrounding area.
- 1.6 The proposals are for one new air source heat pump to be installed on the roof of the main building, along with new PV arrays spread over the roof of the main, Roller City and Library buildings. The proposed location of the new ASHP and PV arrays are shown in Figure 2.
- 1.7 The nearest residential properties to the proposed new plant are the houses on Scholars Mews to the north as indicated in Figure 1.
- 1.8 This assessment has included:
  - Background noise surveys outside the nearest residential properties.
  - Calculation of the likely plant noise levels outside the nearest residential properties.

- A BS 4142:2014+A1:2019 assessment of likely plant noise impact.
- Recommendations for noise mitigation measures.

- 1.9 All recommendations made in this report have been provided for acoustic purposes only. All other aspects of the proposals should be checked by relevant specialists (e.g. fire, structural, mechanical & electrical, etc.).
- 1.10 The various noise units and indices referred to in this report are described in Appendix I. All noise levels mentioned in the text have been rounded to the nearest decibel, as fractions of decibels are imperceptible.

## 2.0 BRITISH STANDARD 4142:2014+A1:2019

- 2.1 British Standard 4142:2014+A1:2019, *Methods for rating and assessing industrial and commercial sound* (referred to hereafter as BS 4142), is appropriate guidance for assessing and controlling the potential noise impact from noise sources such as mechanical services plant installations.
- 2.2 BS 4142 requires a 'rating' level ( $L_{Ar,Tr}$ ) to be calculated from the operation of the noise source and compared with the background sound level ( $L_{A90,T}$ ) which is measured in the absence of the noise source, evaluated over a 1-hour period for daytime operations and a 15-minute period for night-time operations.
- 2.3 The rating level ( $L_{Ar,Tr}$ ) is based on the 'specific' sound level ( $L_s = L_{Aeq,Tr}$ ) attributed to the operating noise source, with 'character corrections' added for sound sources where 'certain acoustic features can increase the significance of impact' at residential locations.
- 2.4 The character correction applied to the specific sound level in order to obtain the rating level can take into account tonality, intermittency, impulsivity and characteristics otherwise distinctive against the prevailing noise climate in the area of the residential properties.
- 2.5 An initial estimate of the potential noise impact from the operating noise source is determined by comparing the difference between the background level and the rating level at the residential locations.
- 2.6 Regarding the outcome of the initial estimate, BS 4142 states that:
- Typically, the greater this difference, the greater the magnitude of impact;
  - A difference of around +10 dB or more is likely to be an indication of a significant adverse impact, depending on the context;
  - A difference of around +5 dB is likely to be an indication of an adverse impact, depending on the context; and,
  - The lower the rating level is relative to the measured background level, the less likely it is that the operation will have an adverse impact or a significant adverse impact. Where the rating level is does not exceed the background sound level, this is an indication of the specific sound source having low impact, depending on the context.

2.7 BS 4142 states that all pertinent factors must be taken into account regarding the context in which the noise occurs, including but not limited to:

- The absolute level of sound.
- The character and level of the residual sound compared to the character of the specific sound; and,
- The sensitivity of the receptor and whether dwellings or other premises used for residential purposes will incorporate design measures that ensure good internal and/or outdoor acoustic conditions such as acoustic screening.

### **EHO Comments on Plant Noise Design Targets**

2.8 We understand from the EHO that the council's requirements as follows:

*"The impact of new plant and equipment should be assessed in accordance with BS4142:2014. When noise sources show signs of tonality, we require noise levels to be 10dB below background noise level at the nearest receptor location. In instances where the noise source presents no tonality, we require the noise level to be 5dB below the background noise level at the nearest receptor location."*

### 3.0 AMBIENT NOISE SURVEY

- 3.1 Attended noise surveys were carried out to quantify the representative background sound levels at the nearest dwellings during sample daytime and evening periods.
- 3.2 Whilst BS 4142 considered the daytime to be a single period between 07:00 and 23:00 and does not make a distinction for the evening, in this case we have based our assessment on separate daytime (07:00-19:00) and evening (19:00-23:00) periods, as the evening hours can be noticeably quieter.
- 3.3 The noise surveys were carried out on Wednesday 9 June 2021, between 14:06 and 16:23 for the daytime period and between 19:53 and 22:07 for the evening period.
- 3.4 The noise surveys were carried out at the nearest dwellings to the proposed new plant (Location A: On Scholars Mews), as shown in Figure 1.
- 3.5 The majority of the COVID-19 lockdown restrictions were lifted during the time of the noise survey, hence, there is considered to be no appreciable effect on the background noise climate.
- 3.6 The sound level measurements were taken in 15-minute periods in 'free-field' conditions, at a microphone height 1.4m above the local ground. Calibration checks were carried out both before and after the noise survey with no variance in calibration level.
- 3.7 Weather conditions during the noise surveys were suitable for sound level measurements. Full details of the weather conditions and the measurement equipment used can be seen in Appendix II.
- 3.8 The results of the ambient noise surveys can be seen in full in Appendix II and a summary showing the range of results is shown in Table 1.

**Table 1: Range of Noise Survey Results (dB)**

Location	Period	$L_{Aeq,15\text{ min}}$	$L_{A90,15\text{ min}}$
Location A: On Scholars Mews	Daytime	43-47	39-41
	Evening	45-46	36-40

- 3.9 The noise climate in the area during the hours of the noise surveys fairly was quiet. The main contributions to the noise climate were distant road traffic noise and bird noise.



## 4.0 ASSESSMENT OF PLANT NOISE

### Plant Noise Design Targets

- 4.1 The objective is to quantify a background sound level which is representative of the noise climate during the period of interest; Section 8.1 of BS 4142 states *“the objective is not simply to ascertain a lowest measured background sound level, but rather to quantify what is typical during particular time periods.”*.
- 4.2 The arithmetic mean of the measured background sound levels is 40 dB  $L_{A90,15 \text{ min}}$  during the daytime and 38 dB  $L_{A90,15 \text{ min}}$  during the evening at Location A, which we have adopted as the representative background sound levels during these periods.
- 4.3 The proposed plant will be brand new equipment, which is to be properly installed by suitably qualified building services engineers and properly maintained there-after. Based on these factors and the even distribution of the manufacturer octave band noise levels, no tonal characteristics are anticipated to be associated with the proposed new plant equipment. Therefore, based on the guidance provided by the EHO, which is discussed in Sections 2, the design targets are 5 dB below the background sound levels.
- 4.4 On this basis, the design targets for the new plant equipment are shown in Table 2.

**Table 2: Plant Noise Design Targets at Location A: Scholars Mews (dB)**

Daytime (07:00-19:00)	Evening (19:00-23:00)
35 $L_{Ar,1h}$	33 $L_{Ar,1h}$

### Proposed New Equipment

- 4.5 Where the original proposals included two ASHPs, the new proposals include only one ASHP which is to be mounted further from the Scholars Mews dwellings, on the main building as shown in Figure 2, along with PV arrays and associated inverters which are to be installed across the three roofs.
- 4.6 The PV arrays themselves do not produce noise of any consequence, but noise from their inverters has been included in the assessment. A summary of the proposed plant is shown in Table 3 along with the manufacturer noise emission data.

**Table 3: Summary of Proposed Plant Noise Emissions**

Reference	Model	Description of Noise Source	Location	dB
ASHP 01	i-FX-N-G05 /SL-A /0652	External Air Source Heat Pump	North-western area of Main Building Roof	95 $L_{wA}$
Inverter (Library)	Solis-30K-5G	External Inverter	Library Roof	30 $L_{pA}$ @ 1m
Inverter (Main)	Solis-25K-5G	External Inverter	Main Building Roof	30 $L_{pA}$ @ 1m
Inverter (Roller)	Solis-50K	External Inverter	Roller City' Roof	60 $L_{pA}$ @ 1m

**Plant Noise Levels at Nearest Dwellings**

4.7 In the process of developing the proposals along with the plant engineers, the following noise mitigation measures have been incorporated into the proposals:

- The SL-A model is the 'super-low noise' model for the output capacity required.
- Only one ASHP will be installed as opposed to the original proposals for two.
- The proposed location of the ASHP has been moved further back from the dwellings.
- A large acoustic barrier around the ASHP has been incorporated into the proposals.
- The ASHP will be programmed to operate during the daytime only, so there will be no noise from the unit during the night.

4.8 Whilst the ASHP is the low noise emission model - which we understand is the lowest noise model available for this capacity, it still generates a fairly significant sound power level under full load, hence why the noise mitigation measures above have been incorporated into the proposals.


4.9 Through our discussions with the plant engineers regarding further noise mitigation options, we understand that they are in talks with Alloway Acoustics, who work closely with manufacturers to incorporate acoustic treatment into the plant machinery, to reduce the sound power output of the ASHP using bespoke acoustic treatments. We have provided them with a noise mitigation target of a minimum of 4 dB(A) reduction, which would result in a sound power level output of 91 dB  $L_{wA}$ .


4.10 The background sound levels at the nearest dwellings are also low, which results in lower noise design targets and the local authority have requested that the noise levels be controlled to within 5dB of the background levels, where no tonal characteristics are anticipated.


- 4.11 We have calculated the anticipated plant noise levels at the most exposed first floor elevations of the nearest dwellings, with different acoustic barrier heights. With a reduced sound power output of 91 dB  $L_{WA}$  and a 3m acoustic barrier as indicated in Figure 3, the noise levels would be 33 dB  $L_{Ar,1h}$  at the most exposed dwelling.
- 4.12 On this basis, taking into account the noise mitigation measures above and the substantial acoustic barrier, it is considered that further reductions of the plant noise levels would be unrealistic and likely prohibitively costly.
- 4.13 The recommended noise mitigation measures would ensure that the plant noise is within the EHO's design targets during daytime and evening operations.
- 4.14 Given the significant noise mitigation measures, subsequent low predicted noise levels and the fact that the ASHP will not operate at night, no adverse noise impact is anticipated and noise should not be a significant factor in the planning decision.

## **5.0 SUMMARY & CONCLUSION**

- 5.1 Hepworth Acoustics Ltd was commissioned by Press & Starkey to carry out a noise impact assessment in connection with a planning application for proposed new externally mounted plant equipment at the Campus West in Welwyn Garden City.
- 5.2 Noise surveys were carried out outside the nearest dwellings to determine the existing representative background sound levels in the area.
- 5.3 Appropriate plant noise design targets have been adopted based on the noise survey results to ensure that the plant noise level is controlled to within an acceptably low level.
- 5.4 The plant noise level at the nearest dwellings has been calculated based on the proposals.
- 5.5 Significant noise mitigation measures have been incorporated into the proposals along with a substantial acoustic barrier to control the noise within the daytime and evening design targets. Furthermore, the ASHP will not operate at night (i.e. 23:00-07:00).







## Appendix I: Noise Units & Indices

### Sound and the decibel

A sound wave is a small fluctuation of atmospheric pressure. The human ear responds to these variations in pressure, producing the sensation of hearing. The ear can detect a very wide range of pressure variations. In order to cope with this wide range of pressure variations, a logarithmic scale is used to convert the pressure values into manageable numbers. Although it might seem unusual to use a logarithmic scale to measure a physical phenomenon, it has been found that the human response to sound most closely follows a logarithmic relationship. The dB (decibel) is the logarithmic unit used to describe sound (or noise) levels. The usual range of sound pressure levels is from 0 dB (at the threshold of hearing) to 120 dB (at the threshold of pain).

Due to the logarithmic nature of decibels, when two sounds of the same level are combined together, the total sound level is (under normal circumstances) 3 dB higher than each of the individual sound levels e.g. 60 dB plus 60 dB = 63 dB. In terms of perceived 'loudness', a 3 dB(A) variation in sound level is a relatively small (but nevertheless just noticeable) change. An increase in sound level of 10 dB(A) generally corresponds to a doubling of perceived loudness. Likewise, a reduction in sound level of 10 dB(A) generally corresponds to a halving of perceived loudness.

The ear is not equally sensitive to sound at all frequencies. It is less sensitive to sound at low and very high frequencies, compared with the frequencies in between. Therefore, when measuring a sound made up of different frequencies, it is often useful to 'weight' the frequency spectrum appropriately, so that the measurement correlates better with what a person would actually hear. This is usually achieved by using a mathematical filter called the 'A' weighting, which is built into sound level meters. Sound levels measured using the 'A' weighting are denoted dB(A) or dBA.

### Frequency and Hertz (Hz)

As well as the loudness of a sound, the frequency content of a sound is also very important. Frequency is a measure of the rate of fluctuation of a sound wave. The unit used is cycles per second, or Hertz (Hz). Sometimes large frequency values are written as kiloHertz (kHz), where 1 kHz = 1000 Hz.

Young people with normal hearing can hear frequencies in the range 20 Hz to 20 kHz. However, the upper frequency limit gradually reduces as a person gets older.



## Glossary of Relevant Sound & Vibration Terms

When a noise level is constant and does not fluctuate, it can be described adequately by measuring the dB(A) level. However, when the noise level varies with time, the measured dB(A) level will vary as well. In this case, it is therefore not possible to represent the noise with a simple dB(A) value. In order to describe noise where the level is continuously varying, a number of other indices can be used. The various indices used in this report, along with other relevant terms are described below.

- $L_p$  This is the 'Sound Pressure Level' which is a logarithmic ratio between a squared sound pressure quantity and the squared human threshold of hearing.
- $L_{pA}$  This is the A-weighted 'Sound Pressure Level', which is the Sound Pressure Level ( $L_p$ ) adjusted to account for the average human hearing response at difference frequencies for a given sound pressure range.
- $L_W$  This is the 'Sound Power Level' which is a logarithmic ratio between a sound power quantity and the human threshold of hearing.
- $L_{WA}$  This is the A-weighted 'Sound Power Level', which is the Sound Power Level ( $L_W$ ) adjusted to account for the average human hearing response at difference frequencies for a given sound power range.
- $L_{Aeq,T}$  This is the A-weighted 'Equivalent Continuous Sound Level' which is an average of the total sound pressure measured over a specified time period. In other words,  $L_{Aeq,T}$  is the level of a steady sound which has the same total (A-weighted) sound pressure as the real fluctuating noise, measured over the same time period. It is increasingly being used as the preferred parameter for most forms of environmental noise.
- $L_{Amax}$  This is the 'Maximum A-weighted Sound Level' that was measured during the monitoring period.  $L_{Amax}$  used in this report refers throughout to  $L_{Amax}$  measured using the fast time weighting of the sound level meter,  $L_{Amax,f}$ .
- $L_{A90,T}$  This is the A-weighted sound level exceeded for 90% of a measurement time period.  $L_{A90,T}$  is used as a measure of background sound level.

**Appendix II: Noise Survey Results**

<b>Date(s)</b>	Wednesday 9 June 2021
<b>Equipment</b>	Rion NA-28 'Class 1' sound analyser (S/N: 00960036) Rion NC-74 'Class 1' sound calibrator (S/N: 00430648) Kestrel 2500 Portable Weather Meter (S/N: 2556870) Tripod
<b>Weather</b>	Daytime: Dry, ~24°C with low winds <3 m.s <sup>-1</sup> and a clear sky Evening: Dry, ~19°C with low winds <2 m.s <sup>-1</sup> and a clear sky

**Location A: On Scholars Mews**

Time		Measured Sound Levels (dB)			Comments
Start	End	$L_{Amax}$	$L_{Aeq,T}$	$L_{A90,T}$	
Daytime					
14:06	14:21	61.5	46.8	41.0	Some distant road traffic noise. Bird noise. Distant vehicle reversing siren. Some distant aircraft noise. Some brief noise from resident down the road moving their bins.
14:21	14:36	66.1	46.8	41.0	Some distant road traffic noise. Bird noise. Distant vehicle reversing siren. Some distant aircraft noise. Distant child shouting. Brief very distant metallic bang no observed effect on $L_{A90}$ .
16:08	16:23	56.2	42.6	39.0	Distant road traffic noise. Bird noise. Some distant aircraft noise. Some noise from children playing nearby.
Evening					
19:53	20:08	60.0	46.2	39.8	Distant road traffic noise. Bird noise. Some distant aircraft noise. Some distant lawn mower noise.
20:20	20:34	59.0	44.7	38.8	Distant road traffic noise. Bird noise. Some distant aircraft noise. Some low level distant noise from people celebrating in garden.
21:51	22:07	64.5	45.0	36.1	Distant road traffic noise. Some bird noise. Some distant aircraft noise. Some level noise from people celebrating in nearby garden. Some low level noise from residents talking in driveway, no noticeable effect on $L_{A90}$ .